

Potable Water Source Lead Sample Analysis Report

State of Illinois Public Act 099-0922

Community Unit School District 201

133 S. Grant, Westmont, IL

Sample ID Number	Client Sample ID Number A= 1st Sample B= 2nd Sample	Sample Location	Source Type	Sample Result (ug/l)
1703H54-001A	South 1A	Business Office Hallway East	Drinking Fountain	ND
1703H54-002A	South 1B	Business Office Hallway East	Drinking Fountain	ND
1703H54-003A	South 2A	Business Office Hallway West	Drinking Fountain	ND
1703H54-004A	South 2B	Business Office Hallway West	Drinking Fountain	2.29
1703H54-005A	South 3A	Early Childhood Hallway	Drinking Fountain - Left Unit	ND
1703H54-006A	South 3B	Early Childhood Hallway	Drinking Fountain - Left Unit	ND
1703H54-007A	South 4A	Early Childhood Hallway	Drinking Fountain - Right Unit	ND
1703H54-008A	South 4B	Early Childhood Hallway	Drinking Fountain - Right Unit	ND
1703H54-009A	South 5A	Gross Motor (Gym) Room E106	Drinking Fountain	4.32
1703H54-010A	South 5B	Gross Motor (Gym) Room E106	Drinking Fountain	ND
1703H54-011A	South 6A	Kitchen - Room E112	Faucet	9.85
1703H54-012A	South 6B	Kitchen - Room E112	Faucet	ND
1703H54-013A	MAN 1A	2nd Floor Hallway South	Drinking Fountain - Right Unit	ND
1703H54-014A	MAN 1B	2nd Floor Hallway South	Drinking Fountain - Right Unit	ND
1703H54-015A	MAN 2A	2nd Floor Hallway Center	Drinking Fountain - Right Unit	ND
1703H54-016A	MAN 2B	2nd Floor Hallway Center	Drinking Fountain - Right Unit	ND
1703H54-017A	MAN 3A	2nd Floor Hallway Center	Drinking Fountain - Center Unit	ND
1703H54-018A	MAN 3B	2nd Floor Hallway Center	Drinking Fountain - Center Unit	ND
1703H54-019A	MAN 4A	2nd Floor Hallway Center	Drinking Fountain - Left Unit	ND
1703H54-020A	MAN 4B	2nd Floor Hallway Center	Drinking Fountain - Left Unit	ND
1703H54-021A	MAN 5A	1st Floor Hallway South	Drinking Fountain	ND
1703H54-022A	MAN 5B	1st Floor Hallway South	Drinking Fountain	ND
1703H54-023A	MAN 6A	1st Floor Hallway Center	Porcelain Drinking Fountain	2.70
1703H54-024A	MAN 6B	1st Floor Hallway Center	Porcelain Drinking Fountain	ND
1703H54-025A	MAN 7A	1st Floor Hallway Center	Drinking Fountain - 1st from Right Unit	ND
1703H54-026A	MAN 7B	1st Floor Hallway Center	Drinking Fountain - 1st from Right Unit	ND
1703H54-027A	MAN 8A	1st Floor Hallway Center	Drinking Fountain - 1st from Left Unit	ND
1703H54-028A	MAN 8B	1st Floor Hallway Center	Drinking Fountain - 1st from Left Unit	ND
1703H54-029A	MAN 9A	1st Floor Hallway Center	Drinking Fountain - Far Left Unit	ND
1703H54-030A	MAN 9B	1st Floor Hallway Center	Drinking Fountain - Far Left Unit	ND
1703H54-031A	MAN 10A	Room 107	Porcelain Drinking Fountain	2.95
1703H54-032A	MAN 10B	Room 107	Porcelain Drinking Fountain	ND
1703H54-033A	MAN 11A	Room 103	Porcelain Drinking Fountain	ND
1703H54-034A	MAN 11B	Room 103	Porcelain Drinking Fountain	ND
1703H54-035A	MAN 12A	Kindergarten Room 101	Drinking Fountain	2.21
1703H54-036A	MAN 12B	Kindergarten Room 101	Drinking Fountain	ND
1703H54-037A	MAN 13A	Outside of Room 12	Drinking Fountain	ND
1703H54-038A	MAN 13B	Outside of Room 12	Drinking Fountain	ND
1703H54-039A	MAN 14A	Kitchen	3 Basin Sink - Left Faucet	ND
1703H54-040A	MAN 14B	Kitchen	3 Basin Sink - Left Faucet	ND
1703H54-041A	MAN 15A	Kitchen	3 Basin Sink - Right Faucet	ND
1703H54-042A	MAN 15B	Kitchen	3 Basin Sink - Right Faucet	ND
1703H54-043A	MAN 16A	Lower Level Hallway Center	Porcelain Drinking Fountain	ND
1703H54-044A	MAN 16B	Lower Level Hallway Center	Porcelain Drinking Fountain	ND
1703H54-045A	MAN 17A	Lower Leve Hallway South	Porcelain Drinking Fountain	3.45
1703H54-046A	MAN 17B	Lower Leve Hallway South	Porcelain Drinking Fountain	ND
1703H54-047A	MAN 18A	Gym Lobby	Porcelain Drinking Fountain	4.73
1703H54-048A	MAN 18B	Gym Lobby	Porcelain Drinking Fountain	4.35
1703H54-049A	MAN 19A	Gymnasium	Drinking Fountain	ND
1703H54-050A	MAN 19B	Gymnasium	Drinking Fountain	ND
1703H54-051A	MIL 1A	Room 200D	Drinking Fountain	4.39
1703H54-052A	MIL 1B	Room 200D	Drinking Fountain	6.39
1703H54-053A	MIL 2A	2nd Floor Hallway East	Drinking Fountain - Right Unit	ND
1703H54-054A	MIL 2B	2nd Floor Hallway East	Drinking Fountain - Right Unit	ND
1703H54-055A	MIL 3A	2nd Floor Hallway East	Drinking Fountain - Left Unit	ND
1703H54-056A	MIL 3B	2nd Floor Hallway East	Drinking Fountain - Left Unit	ND
1703H54-057A	MIL 4A	Room 100C	Drinking Fountain	ND
1703H54-058A	MIL 4B	Room 100C	Drinking Fountain	ND

1703H54-059A	MIL 5A	1st Floor Hallway East	Drinking Fountain - Right Unit	ND
1703H54-060A	MIL 5B	1st Floor Hallway East	Drinking Fountain - Right Unit	ND
1703H54-061A	MIL 6A	1st Floor Hallway East	Drinking Fountain - Left Unit	ND
1703H54-062A	MIL 6B	1st Floor Hallway East	Drinking Fountain - Left Unit	ND
1703H54-063A	MIL 7A	Kitchen - Serving Line Room	Drinking Fountain	ND
1703H54-064A	MIL 7B	Kitchen - Serving Line Room	Drinking Fountain	ND
1703H54-065A	MIL 8A	Kitchen	3 Basin Sink - Right Faucet	ND
1703H54-066A	MIL 8B	Kitchen	3 Basin Sink - Right Faucet	ND
1703H54-067A	MIL 9A	Kitchen	3 Basin Sink - Left Faucet	8.32
1703H54-068A	MIL 9B	Kitchen	3 Basin Sink - Left Faucet	ND
1703H54-069A	JR 1A	Cafeteria	Drinking Fountain - Left Unit	4.23
1703H54-070A	JR 1B	Cafeteria	Drinking Fountain - Left Unit	4.04
1703H54-071A	JR 2A	Cafeteria	Drinking Fountain - Center Unit	3.63
1703H54-072A	JR 2B	Cafeteria	Drinking Fountain - Center Unit	4.80
1703H54-073A	JR 3A	Cafeteria	Drinking Fountain - Right Unit	2.69
1703H54-074A	JR 3B	Cafeteria	Drinking Fountain - Right Unit	ND
1703H54-075A	JR 4A	Kitchen	Food Prep Sink Faucet	ND
1703H54-076A	JR 4B	Kitchen	Food Prep Sink Faucet	ND
1703H54-077A	JR 5A	Gym Vestibule	Drinking Fountain - Right Unit	ND
1703H54-078A	JR 5B	Gym Vestibule	Drinking Fountain - Right Unit	ND
1703H54-079A	JR 6A	Gym Vestibule	Drinking Fountain - Left Unit	ND
1703H54-080A	JR 6B	Gym Vestibule	Drinking Fountain - Left Unit	ND
1703H54-081A	JR 7A	Hallway outside of Room 109	Drinking Fountain	ND
1703H54-082A	JR 7B	Hallway outside of Room 109	Drinking Fountain	ND
1703H54-083A	JR 8A	West Hallway/North	Drinking Fountain - Left Unit	ND
1703H54-084A	JR 8B	West Hallway/North	Drinking Fountain - Left Unit	3.55
1703H54-085A	JR 9A	West Hallway/North	Drinking Fountain - Right Unit	ND
1703H54-086A	JR 9B	West Hallway/North	Drinking Fountain - Right Unit	3.62
1703H54-087A	JR 10A	Room 302A	First Sink - Right side of Room	2.55
1703H54-088A	JR 10B	Room 302A	First Sink - Right side of Room	ND
1703H54-089A	JR 11A	Room 302A	Second Sink - Right side of Room	3.27
1703H54-090A	JR 11B	Room 302A	Second Sink - Right side of Room	ND
1703H54-091A	JR 12A	Room 302A	Right Sink - Back West Wall	3.65
1703H54-092A	JR 12B	Room 302A	Right Sink - Back West Wall	ND
1703H54-093A	JR 13A	Room 302A	Center Sink - Back West Wall	3.67
1703H54-094A	JR 13B	Room 302A	Center Sink - Back West Wall	ND
1703H54-095A	JR 14A	Room 302A	Left Sink - Back West Wall	8.22
1703H54-096A	JR 14B	Room 302A	Left Sink - Back West Wall	ND
1703H54-097A	JR 15A	West Hallway/South	Drinking Fountain - Left Unit	ND
1703H54-098A	JR 15B	West Hallway/South	Drinking Fountain - Left Unit	2.58
1703H54-099A	JR 16A	West Hallway/South	Drinking Fountain - Right Unit	ND
1703H54-100A	JR 16B	West Hallway/South	Drinking Fountain - Right Unit	2.14
1703H54-101A	JR 17A	Sixth Grade Bay Hallway	Drinking Fountain - Far Left Unit	8.62
1703H54-102A	JR 17B	Sixth Grade Bay Hallway	Drinking Fountain - Far Left Unit	6.05
1703H54-103A	JR 18A	Sixth Grade Bay Hallway	Drinking Fountain - 1st to Left Unit	8.03
1703H54-104A	JR 18B	Sixth Grade Bay Hallway	Drinking Fountain - 1st to Left Unit	17.0
1703H54-105A	JR 19A	Sixth Grade Bay Hallway	Drinking Fountain - 1st to Right Unit	9.11
1703H54-106A	JR 19B	Sixth Grade Bay Hallway	Drinking Fountain - 1st to Right Unit	3.47
1703H54-107A	JR 20A	Sixth Grade Bay Hallway	Drinking Fountain - Far Right Unit	8.64
1703H54-108A	JR 20B	Sixth Grade Bay Hallway	Drinking Fountain - Far Right Unit	5.08
1703H54-109A	JR 21A	Room 213	Sink - Left Hand Faucet	ND
1703H54-110A	JR 21B	Room 213	Sink - Left Hand Faucet	ND
1703H54-111A	JR 22A	Room 213	Sink - Right Hand Faucet	2.35
1703H54-112A	JR 22B	Room 213	Sink - Right Hand Faucet	ND
1703H54-113A	JR 23A	East Hallway/South	Drinking Fountain - Left Unit	4.81
1703H54-114A	JR 23B	East Hallway/South	Drinking Fountain - Left Unit	5.35
1703H54-115A	JR 24A	East Hallway/South	Drinking Fountain - Right Unit	ND
1703H54-116A	JR 24B	East Hallway/South	Drinking Fountain - Right Unit	2.04
1703H54-117A	JR 25A	East Hallway/North	Drinking Fountain - Left Unit	ND
1703H54-118A	JR 25B	East Hallway/North	Drinking Fountain - Left Unit	2.30
1703H54-119A	JR 26A	East Hallway/North	Drinking Fountain - Right Unit	ND
1703H54-120A	JR 26B	East Hallway/North	Drinking Fountain - Right Unit	5.61
1703H54-121A	HS 1A	Pool Vestibule	Drinking Fountain - Left Unit	ND
1703H54-122A	HS 1B	Pool Vestibule	Drinking Fountain - Left Unit	ND
1703H54-123A	HS 2A	Pool Vestibule	Drinking Fountain - Right Unit	ND
1703H54-124A	HS 2B	Pool Vestibule	Drinking Fountain - Right Unit	ND
1703H54-125A	HS 3A	Mudroom - Door 13	Drinking Fountain	5.92

1703H54-126A	HS 3B	Mudroom - Door 13	Drinking Fountain	2.18
1703H54-127A	HS 4A	Auditoriun Lobby North	Drinking Fountain - Left Unit	ND
1703H54-128A	HS 4B	Auditoriun Lobby North	Drinking Fountain - Left Unit	ND
1703H54-129A	HS 6A	Kitchen	Prep Sink Faucet - by Walk-In Refrigerator	ND
1703H54-130A	HS 6B	Kitchen	Prep Sink Faucet - by Walk-In Refrigerator	ND
1703H54-131A	HS 7A	Kitchen	Prep Sink Faucet - South Wall	2.43
1703H54-132A	HS 7B	Kitchen	Prep Sink Faucet - South Wall	ND
1703H54-133A	HS 8A	Kitchen Dishroom	3 Basin Sink - Right Faucet	ND
1703H54-134A	HS 8B	Kitchen Dishroom	3 Basin Sink - Right Faucet	ND
1703H54-135A	HS 9A	Kitchen Dishroom	3 Basin Sink - Left Faucet	ND
1703H54-136A	HS 9B	Kitchen Dishroom	3 Basin Sink - Left Faucet	ND
1703H54-137A	HS 10A	Commons - near Room135	Drinking Fountain - Left Unit	ND
1703H54-138A	HS 10B	Commons - near Room135	Drinking Fountain - Left Unit	ND
1703H54-139A	HS 11A	Commons - near Room135	Drinking Fountain - Right Unit	ND
1703H54-140A	HS 11B	Commons - near Room135	Drinking Fountain - Right Unit	ND
1703H54-141A	HS 12A	Home EC - Mezzanine	Drinking Fountain	27.7
1703H54-142A	HS 12B	Home EC - Mezzanine	Drinking Fountain	50.5
1703H54-143A	HS 13A	Home EC Room 216	Student Sink - Left Station Faucet	ND
1703H54-144A	HS 13B	Home EC Room 216	Student Sink - Left Station Faucet	ND
1703H54-145A	HS 14A	Home EC Room 216	Student Sink - 1st from Left Station Faucet	ND
1703H54-146A	HS 14B	Home EC Room 216	Student Sink - 1st from Left Station Faucet	ND
1703H54-147A	HS 15A	Home EC Room 216	Student Sink - 2nd from Left Station Faucet	ND
1703H54-148A	HS 15B	Home EC Room 216	Student Sink - 2nd from Left Station Faucet	ND
1703H54-149A	HS 16A	Home EC Room 216	Student Sink - 3rd from Left Station Faucet	ND
1703H54-150A	HS 16B	Home EC Room 216	Student Sink - 3rd from Left Station Faucet	ND
1703H54-151A	HS 17A	Home EC Room 216	Student Sink - NE Wall	ND
1703H54-152A	HS 17B	Home EC Room 216	Student Sink - NE Wall	ND
1703H54-153A	HS 18A	Home EC Room 216	Instructor Sink Faucet	3.29
1703H54-154A	HS 18B	Home EC Room 216	Instructor Sink Faucet	ND
1703H54-155A	HS 19A	Commons - near Media Center	Drinking Fountain - Left Unit	ND
1703H54-156A	HS 19B	Commons - near Media Center	Drinking Fountain - Left Unit	ND
1703H54-157A	HS 21A	Science Mezzanine	Drinking Fountain	9.53
1703H54-158A	HS 21B	Science Mezzanine	Drinking Fountain	6.22
1703H54-159A	HS 22A	Auditoriun Lobby South	Drinking Fountain - Left Unit	ND
1703H54-160A	HS 22B	Auditoriun Lobby South	Drinking Fountain - Left Unit	ND
1703H54-161A	HS 23A	Auditoriun Lobby South	Drinking Fountain - Right Unit	ND
1703H54-162A	HS 23B	Auditoriun Lobby South	Drinking Fountain - Right Unit	ND
1703H54-163A	HS 24A	Fine Arts Hallway	Drinking Fountain	ND
1703H54-164A	HS 24B	Fine Arts Hallway	Drinking Fountain	ND
1703H54-165A	HS 25A	Athletic Trainer Room	Sink Faucet	ND
1703H54-166A	HS 25B	Athletic Trainer Room	Sink Faucet	ND
1703H54-167A	HS 26A	Pool Deck	Drinking Fountain - near Boys Locker Room	4.91
1703H54-168A	HS 26B	Pool Deck	Drinking Fountain - near Boys Locker Room	ND
Legend	South	South Early Childhood Center		
	MAN	Manning Elementary		
	MIL	Miller Elementary		
	JR	Westmont Junior High		
	HS	Westmont High School		